



STATE OF WASHINGTON

DEPARTMENT OF ECOLOGY

15 West Yakima Avenue, Suite 200 • Yakima, Washington 98902-3452 • (509) 575-2490

November 16, 2001

George Rashford
3321 Roza Dr
Zillah WA 98953

RE: Application No(s). G4-32979

Earlier this year, the Department of Ecology issued an Emergency Drought Authorization under the above-referenced application number for the use of emergency wells in the Yakima River basins to supplement reduced deliveries during this irrigation season. In some cases new wells were approved for this purpose.

One of the provisions of the authorizations was that a flow meter must be installed, water use monitored, and the water use records submitted to the department at the end of the irrigation season. At this time, I am writing to request the metering reports on these wells. If you did not drill a well that was authorized, or did not use water that was authorized, please let us know.

My staff will be conducting end of irrigation season field visits in the near future. Your meter records and information on the completion of new wells is greatly appreciated.

If you have questions, please call Suzanne Blakeney at (509) 454-7294.

Sincerely,

Phil Crane, Unit Supervisor
Water Resources Program

SB:PC:gg
011110a



Drought Field Checklist

ZILLAH

24 MAY 2001
Date of Field Visit
64-32979
Certificate / Permit Number
509 829 5182
Phone Number

N 46° 26' 28.3" W 128° 15' 31.7"
GPS Reading
RASH ROAD
Certificate / Permit Name
MAG RASH ROAD
Contact Name

METER (WATER and/or ELECTRICAL) INFORMATION:

YES _____ Type: _____ Reading: _____
Type: _____ Reading: _____
Type: _____ Reading: _____
NO _____ Describe alternative measuring technique: _____

METER NOT WORKING - LAST READING 068009
NO MUFFLER ON DIESEL ENGINE, ONLY SITE
110 HP TURBINE
8" to 6" with meter to 5" main

How many users are on the electrical meter: NO METER

PUMP INFORMATION: (Should be a tag on the pump)

Type: _____ HP: _____ Head Discharge: _____
Other pump information: _____

General Notes: EXTREMELY LOUD DIESEL DRIVE - NO MUFFLER.
METER APPEARS TO BE BROKEN.

Contacts' Questions: _____

KERR/PERLOW
Inspector Name

Inspector Name



STATE OF WASHINGTON

DEPARTMENT OF ECOLOGY

15 West Yakima Avenue, Suite 200 • Yakima, Washington 98902-3452 • (509) 575-2490

May 7, 2001

To: Carroll Palmer, Yakama Nation

RE: Emergency Drought Permit re: George B Rashford
(G4-32979)

Enclosed is a copy of the Department of Ecology's Emergency Drought Permit, which constitutes our determination and order regarding the above-referenced application. If you have any questions or concerns about any of this information, please call Carol Mortensen of the Department of Ecology at (509) 575-2597.

This Order may be appealed pursuant to RCW Chapter 43.21B. The person to whom this Order is issued must file an appeal with the Pollution Control Hearings Board within thirty (30) days of receipt of this Order. Send the appeal to: Pollution Control Hearings Board, P.O. Box 40903, Olympia, Washington 98504-0903. At the same time, a copy of the appeal must be sent to: Department of Ecology, Fiscal Office, P.O. Box 47615, Olympia, Washington 98504-7615. All others receiving notice of this Order must file an appeal with the Pollution Control Hearings Board within thirty (30) days of the date the Order was mailed in the same manner described above.

Sincerely,

Robert F. Barwin, Section Manager
Water Resources Program

RFB:gg
010511a

Enclosures: Emergency Drought Permit

f-10th.doc

